



Tolerance	
<3.00	±0.01
>3.00	±0.02

FM-DD-04

UNIT = METER




AIR BLOWER 1 (For EQ.& Aeration) : "Unomach" model ARC-50, 1.93 m³/min@3000mmAq , 2.2kw.x 1Set

AIR BLOWER 2 (For Sedimentation) : "Unomach" model ARS-32, 0.60 m³/min@3000mmAq , 0.75kw.x 1Set

UNCONTROLLED DOCUMENT

Client							โครงการ เทวาศรม เขาหลัก รีสอร์ท								
Title						STAR TANK MODEL SK30070-B						Scale		Title	
														NTS.	
Drawn		Date		Approved		Date		Drawing No.		Rev.					
Chonticha K.		30-10-60		Wassana		30-10-60		Fac_248/60		Rev.0					



PROUD
ASIA